



88 Empire Drive • St. Paul, Minnesota • 55103  
 (651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

June 21, 2012

Supplier: Hilti Entwicklungsgesellschaft mbH  
 BU Anchors  
 Hiltistrasse 6  
 86916 Kaufering  
 GERMANY

Sample Description: Hilti CFS-S SIL Firestop Silicone Sealant (Low Density)

Date Tested: May 23, 2012

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
<b>LEED 2009 (LEED 3.0)</b> <b>LEED 2.2</b> IEQ-4.1: Low-Emitting Materials – Adhesives and Sealants	<b>Hilti</b> <b>CFS-S</b> <b>SIL Silicone Sealant</b> <b>(Low Density)</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Architectural Sealant;</b> <b>VOC Limit: 250 g/L</b>	
	<b>Product contains: 0.32 g/L of VOC</b>

Tom Barrett  
 Vice President/Strategic Analytical Services

Kelly French  
 Chemist III/Dept. Manager