



88 Empire Drive • St. Paul, Minnesota • 55103  
(651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

March 17, 2023

Supplier: Hilti Entwicklungsgesellschaft mbH  
BU Chemicals  
Hiltistrasse 6  
86916 Kaufering  
GERMANY

Sample Description: CFS-CID U (Inlay Material)

Date Tested: February 09, 2023

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
<b>LEED 4.1</b> Low-Emitting Materials – Adhesives and Sealants	<b>CFS-CID U</b> <b>(Inlay Material)</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Architectural Sealants</b> VOC Limit: 250 g/L	<b>Product contains: 3 g/L of VOC</b>

---

Tom Barrett  
Vice President/Strategic Analytical Services